


16.6.3 and 16.6.3.1 are regarded in the fire fighting industry as requiring that fire fighting pumps come equipped with a 2.5" or pony inlet. Both submission are relevant to the Examiner's new comment regarding pump inlet sizes.

Respectfully Submitted,

8/18/6
Date


Sue Z. Shaper
Attorney/Agent for Applicant(s)
Reg. No. 31663

Sue Z. Shaper
1800 West Loop South, Suite 1450
Houston, Texas 77027
Tel. 713 550 5710